

## 530/630/730 En/EnN EDS compatibility guide

**Table 1 - EDS compatibility guide — 530/630/730 En/EnN**

EDS file (Found on website)	EDS release Date	Compatible with pump software versions	Version comments
530/630/730 EtherNet/IP EDS Rev 2.1 control file	March 2020	0.26.02	Initial EDS release
530/630/730 EtherNet/IP EDS Rev 2.2 control file	November 2020	0.27.04 0.27.05	Addition of asset number (parameter 63), Error Acknowledge (parameter 64), RPI range (parameter 65), parameter re-ordering
530/630/730 EtherNet/IP EDS Rev 2.5 control file	February 2022	0.41.03 0.42.03 0.43	Addition of PressureSwitchError (parameter 106), use of bit 7 in general alarm for PressureSwitchError, use of bit 6 in general alarm for DispenseInterrupted, AssetNumber (parameter 63) moved to acyclic data records, parameter 61 and 62 name change to AnybusNetworkMode and AnybusNetworkActive,

Link to EDS file location:

1. Navigate to: <https://www.wmfts.com/softwareanddevices/>

**Notes:**

1. If your pump software is compatible with multiple EDS files versions it is recommended to use the latest version available.
2. In order to find your pump software version, select **Help**, then **Software** on your pump
3. The correct EDS file version must be used in combination with the pump software versions listed for good communication between the pump and control system.
4. Networks using pumps with different software and EDS versions are acceptable as long as each pump is using the correct EDS version